

April 29, 2020

Engineering  
1630 Robin Circle  
Forest Hill, MD 21050  
Attn: Christopher Mink, P.E.

RE: BGE – Ingleside, Phase I, Gas Main Replacement  
Stormwater Management Variance  
Patapsco River and Gwynns Falls Watersheds  
**Project I.D. M200118**  
**Tracking Number: 01-20-3221**

Dear Mr. Mink;

This office has reviewed the information submitted and finds that a stormwater management variance can be granted for this project under Section 33-4-113 (a) (2) of Title 4 of the Baltimore County Code. Section 33-4-113 (a) (2) allows a stormwater management variance to be granted if there are exceptional circumstances such that strict adherence to the provisions of the design standards would result in unreasonable hardship and not fulfill the intent of the regulations.

This project is for upgrading an existing low pressure gas system to a high pressure system, and installing gas mains by cut and cover. The existing cover conditions will be re-established once the gas mains are installed. Although the disturbed area is in excess of 5,000 square feet, there will be no increase in impervious area or runoff resulting from the project.

Please contact Jeannette Applauso, P.E. at 410-887-3768 should you have any questions.

Very truly yours,

*/signed/*

Kritty Udhin, P.E., Manager  
Stormwater Management  
Department of Environmental Protection  
& Sustainability

KU:jma